



City of Parkland Building Division Window/Door Product Approval Schedule

Job Info		Name	Royale Parkland Elevations A, B, C Models Verna								Permit #	1507-0177					
		Address								Lot / Block	424		Subdivision	Parkland Four Seasons			
Window Door ID #	Window Callout	Rough Opening Size (w x h)	Windows and Doors										Mullion Bars				
			Overall maximum tested size from NOA (w x h)	Design Pressure per Product Approval		Structural Site Specific Design Pressure		Zone Int 4 End 5	Shutter Req'd.	Anchor Type Size Sleeve Anchor 24" O/C 6" from Ends	Anchor Spacing Edge & 24" O.C.			Horiz. Vert.	NOA #	Span in inches	
				(+) psf	(-) psf	(+) psf	(-) psf				Header	Sides	Sill				
2	8080 OHGD	96 x 96	7170.2	16' x 14'	38	42	35.8	39.9	---	no	3/8 x 2 3/4"	---	6"	ends			
3	12080 SGD	144 x 96	20-0427.11	240 X 96	65	65	36.9	41.5	4	no	1/4" X 2 3/4"	C4+2	8	C4+2			
4	(3) 6014 TR	144 x 15.96	20-1223.01	48 X 96	80	80	37.4	42.3	4	no	1/4" X 2 3/4"	4	2	---	Vert	20-1118.13	15
7	6080 DOOR	72 x 96	20-0427.06	74.50x98.00	50	50	38.0	41.6	4	no	#10-2-1/2" PFH wd screw	3	6	3			
8	6026 TR	72 x 30	20-1223.01	48 X 96	80	80	41.3	44.9	4	no	1/4" X 2 3/4"	4	2	---			
10	1/2 34 SH	27.96 x 51	17-1114.07	53 1/8 X 76	80	80	42.3	45.8	4	no	1/4" X 2 3/4"	2	4	0			
14	26SH	36 x 72	17-1114.07	53 1/8 X 76	80	80	40.8	44.3	4	no	1/4" X 2 3/4"	2	4	0			
22	4020 FIXED	48 x 24	20-1223.01	48 X 96	80	80	42.3	45.8	4	no	1/4" X 2 3/4"	4	2	---			
23	2330 FIXED	27 x 36	20-1223.01	48 X 96	80	80	42.3	45.8	4	no	1/4" X 2 3/4"	4	2	---			
28	1/2 36 SH 26SH 1/2 36 SH	92.04 x 76.08	17-1114.07	53 1/8 X 76	80	80	37.9	42.2	4 & 5	no	1/4" X 2 3/4"	2	4	0	Vert	20-1118.13	75
29	2314/3214/2314 TR	92.04 x 15.96	20-1223.01	48 X 96	80	80	42.3	46.7	4 & 5	no	1/4" X 2 3/4"	4	2	---	Vert	20-1118.13	15
30	26SH (3)	108 x 72	17-1114.07	53 1/8 X 76	80	80	37.7	41.3	4	no	1/4" X 2 3/4"	2	4	0	Vert	20-1118.13	75
34	3214 TR (3)	108 x 15.96	20-1223.01	48 X 96	80	80	41.9	45.4	4	no	1/4" X 2 3/4"	4	2	---	Vert	20-1118.13	15
MULL			20-1118.13		115.5	115.5				no	1/4 X 2-3/4						

Rev. 12/30/2021

Approved by A/E of Record

	SHOP STAMP REVIEW	Lot # 424
Review is for general compliance with the Construction Documents. Sole responsibility for correctness of dimensions, details, quantities, and safety during fabrication Contractor.		
<input checked="" type="checkbox"/> No Exceptions Taken	Reviewed By: 	Date: 05/11/2022
<input type="checkbox"/> Rejected: _____		