


City of Parkland Building Division Window/Door Product Approval Schedule												
Window Door ID #	Name Address Rough Opening Size (w x h)	Windows and Doors						Shutter Reql.		Mullion Bars		Span in inches
		Product Approval NOA #		Design Pressure per Product Approval		Structural Site Specific Design Pressure		Yes	No	NOA #	Permit #	
		(+) psf	(-) psf	(+) psf	(-) psf	(+) psf	(-) psf	NO	NO	NOA #	Permit #	
A	76 * 24	22-0105.01	80.0	80.0	80.0	80.0	38.3	-51.3	NO	NO	N/A	
B	38 * 72	21-0526.02	65.0	80.0	80.0	80.0	36.7	-40.0	NO	NO	N/A	
C	38 * 16	22-0105.01	80.0	80.0	80.0	80.0	38.3	-51.3	NO	NO	N/A	
D	90 * 38	21-0526.02	65.0	80.0	80.0	80.0	37.6	-40.9	NO	NO	N/A	
E	114 * 72	21-0526.02	65.0	80.0	80.0	80.0	34.0	-37.2	NO	NO	VERT	20-1118.13
F	114 * 16	22-0105.01	80.0	80.0	80.0	80.0	37.2	-40.4	NO	NO	VERT	20-1118.13
I	74 * 20	22-0105.01	80.0	80.0	80.0	80.0	36.6	-47.8	NO	NO	VERT	20-1118.13
J	76 * 16	22-0105.01	80.0	80.0	80.0	80.0	38.2	-51.0	NO	NO	VERT	20-1118.13
K	38 * 72	21-0526.02	65.0	80.0	80.0	80.0	35.0	-44.7	NO	NO	VERT	20-1118.13
L	38 * 16	22-0105.01	80.0	80.0	80.0	80.0	38.3	-51.3	NO	NO	N/A	
M	38 * 72	21-0526.02	65.0	80.0	80.0	80.0	36.7	-40.0	NO	NO	N/A	
N	38 * 16	22-0105.01	80.0	80.0	80.0	80.0	38.3	-51.3	NO	NO	N/A	
O	38 * 72	21-0526.02	65.0	80.0	80.0	80.0	36.7	-40.0	NO	NO	N/A	
P	48 * 28	22-0105.01	80.0	80.0	80.0	80.0	38.5	-41.6	NO	NO	N/A	
Q	48 * 48	22-0105.01	80.0	80.0	80.0	80.0	38.3	-51.3	NO	NO	N/A	
R	48 * 16	22-0105.01	80.0	80.0	80.0	80.0	38.3	-51.3	NO	NO	N/A	
T	27 * 38	21-0526.02	65.0	80.0	80.0	80.0	38.3	-51.3	NO	NO	N/A	
EE	76 * 72	22-0105.01	65.0	80.0	80.0	80.0	35.0	-44.7	NO	NO	VERT	20-1118.13
FF	38 * 20	22-0105.01	65.0	80.0	80.0	80.0	37.4	-49.5	NO	NO	VERT	20-1118.13
HH	96 * 20	22-0105.01	80.0	80.0	80.0	80.0	38.2	-51.0	NO	NO	VERT	20-1118.13
D1	192 * 96	20-1015.40	80.0	80.0	80.0	80.0	37.3	-40.5	NO	NO	N/A	
D2	96 * 96	20-1015.27	60.0	60.0	60.0	60.0	33.8	-42.2	NO	NO	N/A	
D3	72 * 96	FL-20470.12	60.0	60.0	60.0	60.0	34.7	-37.7	NO	NO	N/A	
D4	148 * 96	22-0118.05	60.0	60.0	60.0	60.0	32.8	-36.1	NO	NO	N/A	
D5	32 * 96	19-0918.03	43.6	43.6	43.6	43.6	36.3	-39.5	NO	NO	N/A	
D6	96 * 96	22-0118.05	60.0	60.0	60.0	60.0	32.8	-36.1	NO	NO	N/A	



FEB 13 2023

Approval by A/E of Record
 Design Prof: Architect Cert No. A0012079 Seal:
 Signature: _____

D1



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/building

Amarr Garage Doors dba Entrematic

165 Carriage Court
Winston Salem, NC 27105

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in MiamiDade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Model 650 Oak Summit, 600 Stratford & 950 Heritage Series 1000 & 2000 Steel Sectional Garage Door up to 16'-0" Wide w/ Impact Resistant Windows – L.M.I.

APPROVAL DOCUMENT: Drawing No. **IRC-6016-156-26-I**, titled "Model #650 Oak Summit, #600 Stratford and #950 Heritage Series 1000 & 2000", sheets 1 through 3 of 3, dated 02/05/14, prepared by manufacturer, signed and sealed by Thomas L. Shelmerdine, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, manufacturing address, model number, the positive and negative design pressure rating, indicate impact rated if applicable, installation instruction drawing reference number, approval number (NOA), the applicable test standards, and the statement reading 'Miami-Dade County Product Control Approved' is to be located on the door's side track, bottom angle, or inner surface of a panel.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.


ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 19-0911.04 and consists of this page 1 and evidence page E-1, E-2 and E-3, as well as approval document mentioned above.

The submitted documentation was reviewed by **Manuel Perez, P.E.**




1/22/21

NOA No. 20-1015.40
Expiration Date: September 25, 2024
Approval Date: January 28, 2021
Page 1