



**City of Parkland Building Division Window/Door Product Approval Schedule**

Job Info		Name	Royale Parkland Elevation C Model Bianca								Permit #	1507-0177					
		Address									Subdivision	Parkland Four Seasons					
		Windows and Doors										Mullion Bars					
Window Door ID #	Window Callout	Rough Opening Size (w x h)		Overall maximum tested size from NOA (w x h)	Design Pressure per Product Approval		Structural Site Specific Design Pressure		Zone Int 4 End 5	Shutter Req'd.	Anchor Type Size Sleeve Anchor 24" O/C 6" from Ends	Anchor Spacing Edge & 24" O.C.			Mullion Bars		
					(+) psf	(-) psf	(+) psf	(-) psf				Header	Sides	Sill	Horiz. Vert.	NOA #	Span in inches
1	16080 OHGD	192 x 96	7170.2	16' x 14'	38	42	33.6	37.4	---	no	3/8 x 2 3/4"	---	6"	ends			
2	8080 OHGD	96 x 96	7170.2	16' x 14'	38	42	33.7	37.5	---	no	3/8 x 2 3/4"	---	6"	ends			
5	2880 DOOR	32.04 x 96	20470.5	37.75x98.00	55	55	38.0	41.3	4	no	#10-2-1/2" PFH wd screw	3	6	3			
6	(2) 26 SH	76.08 x 76.08	21-0526.02	531/8 X 76	80	80	36.4	39.8	4	no	1/4" X 2 3/4"	2	4	0			
7	26 SH	38.04 x 76.08	21-0526.02	531/8 X 76	80	80	38.1	41.4	4	no	1/4" X 2 3/4"	2	4	0			
8	H 36 SH	27.96 x 75	21-0526.02	531/8 X 76	80	80	39.0	42.4	4	no	1/4" X 2 3/4"	2	4	0			
9	60100 SGD	72 x 120	22-0118.05	240 X 96	60	60	35.3	38.7	4	no	1/4" X 2 3/4"	C4+2	8	C4+2			
10	120100 SGD	144 x 120	22-0118.05	240 X 96	60	60	33.7	37.1	4	no	1/4" X 2 3/4"	C4+2	8	C4+2			
14	16 TR	36 x 15.96	22-0105.01	48 X 96	80	80	39.9	43.2	4	no	1/4" X 2 3/4"	4	2	---			
15	(3) 16 TR	108 x 15.96	22-0105.01	48 X 96	80	80	39.5	42.9	4	no	1/4" X 2 3/4"	4	2	---			
16	(2) 16 TR	72 x 15.96	22-0105.01	48 X 96	80	80	39.9	43.2	4	no	1/4" X 2 3/4"	4	2	---			
17	H36SH-26SH-H36SH	93.96 x 76.08	21-0526.02	531/8 X 76	80	80	35.7	39.0	4	no	1/4" X 2 3/4"	2	4	0			
19	3016 FIXED	36 x 18	22-0105.01	48 X 96	80	80	39.9	43.2	4	no	1/4" X 2 3/4"	4	2	---			
20	3080 DOOR W/(2) SL	72 x 96	20470.5	37.75x98.00	55	55	35.8	39.2	4	no	#10-2-1/2" PFH wd screw	3	6	3			
21	2030 FIXED	24 x 36	22-0105.01	48 X 96	80	80	39.9	43.2	4	no	1/4" X 2 3/4"	4	2	---			
22	(2) 26 SH	76.08 x 76.08	21-0526.02	531/8 X 76	80	80	36.4	39.8	4	no	1/4" X 2 3/4"	2	4	0			
23	4020 FIXED	48 x 24	22-0105.01	48 X 96	80	80	39.9	43.2	4	no	1/4" X 2 3/4"	4	2	---			
26	6020 TR	72 x 24	22-0105.01	48 X 96	80	80	39.5	42.9	4	no	1/4" X 2 3/4"	4	2	---			
MULL			20.1118.13		115.5	115.5				no	1/4 X 2-3/4						

Rev. 5/5/2022

Approved by A/E of Record

 <b>Fieldstone</b>	<b>SHOP STAMP REVIEW</b>	Lot # 432
Review is for general compliance with the Construction Documents. Sole responsibility for correctness of dimensions, details, quantities, and safety during fabrication Contractor.		
<input checked="" type="checkbox"/> No Exceptions Taken	Reviewed By: 	Date: 02/14/2023
<input type="checkbox"/> Rejected: _____		